

SUPPLY AND INSTALLATION OF 2 NOS. 100KVA DG SET

| SI. | DESCRIPTION | QTY | Rate | Amount |
|------------|---|------------|-------------|---------------|
| 1 | Supply and Installation 100 kVA silent D.G. set, Engine Model KN100 II ,duly coupled with Three Phase 100 kVA /415 V, 139 Amp, alternators mounted on a Common MS channel base frame including STANDARD MANUAL Control Panel, Fuel Tank, and Battery with leads and with Acoustic Enclosure. | 2 | | |
| | Rate should also include cost of | | | |
| | 1. Supply and installation of 200 Amps Change Over Switch alongwith Laying of Power Cable One run 3.5 Core, 120 sq mm,aluminum armored supply & Laying(600 mm trench depth w ith send & bricks.) aprox cable length is 30 mtr. As per Specification | | | |
| | 2. 4 no. Copper Earthing Pit supply Materials & Labour (5mm 300x300 mm copper plate,25x5 strip for each DG set. | | | |
| | Grand Total | | | |